



Winter Operation of a 65-Watt Methanol Fuel Cell at an Unattended Arctic Site

Roy Stehle

SRI International
Center for GeoSpace Studies
Menlo Park, CA 94025
roy.stehle@sri.com 650-859-2552

***Polar Technology Conference
Albuquerque, NM
25 March 2011***


Proof of Concept of DMFC

- ❑ **Clean power source for carbon flux research sites**
 - **Small amounts of Water and Carbon Dioxide are byproducts**
- ❑ **All-year operational potential**
- ❑ **Study thermal management, air exchange, and problems of water production in $<0\text{ }^{\circ}\text{C}$ environments**
- ❑ **Enhanced broadband communications network for Imnavait Creek research area to retrieve large research data files**

Anode: $\text{CH}_3\text{OH} + \text{H}_2\text{O} \rightarrow 6 \text{H}^+ + 6 \text{e}^- + \text{CO}_2$


Cathode: $3/2 \text{O}_2 + 6 \text{H}^+ + 6 \text{e}^- \rightarrow 3 \text{H}_2\text{O}$

Overall: $\text{CH}_3\text{OH} + 3/2 \text{O}_2 \rightarrow 2 \text{H}_2\text{O} + \text{CO}_2$




Imnavait Creek Communications Node

- East of Toolik Field Station along Dalton Highway



Broadband Internet Point of Presence

- ❑ HughesNet broadband geostationary satellite link
- ❑ IEEE 802.11 terrestrial WLAN



Imnavait Creek Communications Node


- ❑ **65-Watt EFOY Pro 1600 Fuel Cell for winter power**
 - Wind power not reliable in Interior Alaska in winter
 - 40-Watt PV panel for Spring – Fall primary power



Ambient Temperatures at Ridge Site

- System running well at -39 °C
 - System ran well in California at ~ 20 °C


Ambient Temperatures at Innavait Creek




IRP “Grizzly” Enclosure




- ❑ **Exterior**
 - 57 x 31 x 30”
- ❑ **Internal capacity**
 - 384 lbs prepared game
 - 520 12-oz cans
- ❑ **R5 value increased with foam**



Comms Node Interior – Intake Side



Comms Node Interior – Exhaust Side



Water Vapor Tube with Heater



Heat Shrink Tubing

Stainless steel tube with 10-W heater

Conformal Heat Shrink over heater



Finished Exterior End



Installed Vapor Port Tube w/ Heater

- ❑ **Inclined to ensure water runoff**
- ❑ **Internal flexible tubing has no positive slope**
- ❑ **Fuel cell errors indicate when tube is blocked with ice**
 - **Run deicing heater cycle before restarting fuel cell operation**

Finished Exterior End



Finished Interior End



Vapor Port Icicle Formation

❑ **15 December 2010**



Vapor Port Icicle Growth

- ❑ 21 January 2011
- ❑ Fuel is mostly water that needs to be shed
- ❑ Some designs retain the water inside the enclosure
 - Raises internal humidity
 - Interior must stay warm



Water Vapor Icicle

28 October 2010




15 December 2010




Overheating Event Causes Fault

- ❑ Restricted air intakes to keep warm air inside
- ❑ Interior temperature exceeded EFOY spec
- ❑ Service fluid reservoir dried out, shutting down fuel cell before SRI could limit run time
- ❑ Interior drops to ambient and **stack freezes**




Frozen Stack Power Recovery

- ❑ Initial operation very pessimistic (~1 Amp)
- ❑ Present operation restored to ~85% of previous output



Service Fluid Replenishment

- Only during normal Run cycle; **not always for Self Heating runs (May correlate w/ fully charged battery)**
- Undocumented log command provides critical data



```

Tst 22.1C
Tint 23.4C
Twt 22.9C
Tdcdc 24.3C
Tpcb 24.8C
Tres 23.6C
Ubat 12.29V
Uaus 12.26V
Uklemm 12.26V
Ust 1.76V
Uzell 88mV
IntSteIU 0.000e+00n
laus 0.00A
lst 0.00A
FuelSt 70.1n
LastError 1n
Error 0n
StBtrb 0.00h
SysBtrb 82.02h
PcStack 0n
PcMedien 0n
AdW 0n
ResF 0n
DHV 110.00n
DC-DC 0.0%
ULF1 0.0V
Tbt1 24.3C
Uref 2.48V
Ubb 3.02V
FS 0n
SysTime 2009-07-
22_12:47:24

```

Need Closed Vents When Not Running


- ❑ **Differential pressure across enclosure causes cold ambient wind to blow into enclosure vents**
- ❑ **Linear actuator driving**
 - **Aircraft heater box (damper)**
 - **Sliding air port**



Elevated Support

- ❑ **Eliminates drifting snow that could clog air ports**

Communications Node



RE Power Station



Conclusions

- ❑ **Proper thermal and water management permits winter operation of a fuel cell**
 - **Heated Water Vapor port is mandatory**
- ❑ **Open ports caused extra fuel (70%) to be used**
 - **This system projected to burn ~ 50 liters of Methanol / year**
- ❑ **Need to monitor Service Fluid level to prevent unrecoverable stack failure/freezing**
- ❑ **Elevated enclosure prevents drifts from forming and blocking air ports**
- ❑ **Occasional control fight between fuel cell and SBC**
 - **Control algorithm could get very complex**